Door Location (as per floor plan)	Door Type	Door Number (as per photo schedule)	r Swing Handir	NS FSC Chain of Custody	Fire Performance	Glazing Type and Specification	Lipping Species	Threshold Gap	Door Face Material	Door Finish	Frame Type	Frame Finish	Automatic or Self Closing	Meeting Styles	Finger Guard	Fire Signage	Loose ironmongery	Handle and / or Lock details	Ironmongery Finish	Retention of Mag Lock	Removal & Reinstatement of Electrical	Operation			Γ
			Single Both	FSC	Consider FD30 (not required)	None	Hardwood		OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	None	Handle (one side) push and kick plates (both sides), mechanical door closer. Half	D Pull Handle (300mm)	SAA	No	No	Toilet Door	Notes Intumescent strips not required	Further Info	ľ
ST 0019 - GT0020	Door & Half	1	Single Both	FSC	Consider FD30	None	Hardwood		DAK	Veneer	Bullnose Architrave	Dak	Self Closing	Square	Yes	None	door to be fitted with flush bolts Handle (one side) push and kick plates (both sides), mechanical door closer. Half	D Pull Handle (300mm)	SAA	No	No	Toilet Door	Intumescent strips not required		┼
BT0021 - LO0023	Door & Half	2			(not required)	Strip (1450mm x 150mm) 7mm											door to be fitted with flush bolts Dorgard Standard Fire Door Retainer, mechanical door	o run nanos (soonny				(inc disabled access)	Intumescent strips to be filted		+
CR0018 - CO0025	Door & Half	3	Single Both	FSC	FD30s	clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004 (full door only)	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Cak	Automatic	Square	Yes	ves (automatic fire door keep clear)	closer, pull handles (one side), kickplates, pushplates (both sides). Half door to be fitted with flush bolts	D Pull Handle (300mm)	SAA	Yes	Yes	Corridor / Access	to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)		
			Single Both	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004 (full door only)	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Dak	Automatic	Square	Yes	Yes (automatic fire door keep clear)	Dorgard Standard Fire Door Retainer, mechanical door closer, pull handles (one side), kickplates, pushplates (both sides). Half door to be fitted	D Pull Handle (300mm)	SAA	Yes	Yes	Corridor / Access	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)		
C00025 - LD0028	Door & Half	4				Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN										Yes	with flush bolts Dorgard Standard Fire Door Retainer, mechanical door closer, pull handles (one side),						Intumescent strips to be filted to both frames and doors		+
LD0028 - CL0029	Door & Half	5	Single Both	FSC	FD30s	1634-1:2014 & BS EN 12600:2004 (full door only)	Hardwood	3mm to BS 476 Part 31	OAK.	Veneer	Bulinose Architrave	Oak	Automatic	Square	Yes	(automatic fire door keep clear)	kickplates, pushplates (both sides). Half door to be fitted with flush bolts	D Pull Handle (300mm)	SAA	Yes	Yes	Corridor / Access	(Intumescent seals should combine cold smoke brush seals for FD30s)		_
CD0036-LD0028	Door & Half	6	Single Both	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1-2014 & BS EN 12600-2004 (full door only)	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Oak	Automatic	Square	Yes	Yes (automatic fire door keep clear)	Retainer, mechanical door closer, pull handles (one side), kickplates, pushplates (both sides). Half door to be fitted with flush bolts	D Pull Handle (300mm)	SAA	Yes	Yes	Corridor / Access	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)		
GR0031-CD0036	Door & Half	7	Single LH	FSC	FD30s	Square (450mm x 450mm) 7mm dear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bulinose Architrave	Oak	Free Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer. Half door to be fitted with flush bolts Push and kick plates (both	Lever on rose handles with push button code & tubular latch	SAA	No	No	Office	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)		
CD0036-GT0033	Single	8	Single RH	FSC	Consider FD30 (not required)	None	Hardwood		DAK	Veneer	Bullnose Architrave	Oak	Self Closing	Square	Yes	None	sides), mechanical door closer, pull handle (one side)	D Pull Handle (300mm)	SAA	No	No	Tollet Door	Intumescent strips not required		_
CD0036-8T0034	Single	9	Single LH	FSC	Consider FD30 (not required)	None	Hardwood		OAK	Veneer	Bullnose Architrave	Oak	Self Closing	Square	Yes	None	Push and kick plates (both sides), mechanical door closer, pull handle (one side)	D Pull Handle (300mm)	SAA	No	No	Tollet Door	Intumescent strips not required		
CR0038-CD0036	Single	10	Single RH	FSC	FD30s	Oblong Glass Pane (760mmx150mm) 7mm clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bulinose Architrave	Dak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, 1no deadlock, mechanical door closer	Lever on rose handles with escutchean key profile and DLO3 Mortice Sashlock 3 Lever	SAA	No	No	Classsroom Door	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)	Master Key Required	
CR0040-CO0039	Single	11	Single RH	FSC	FD30s	Oblong Glass Pane (760mmx150mm) 7mm dear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004 Oblong Glass Pane	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bulinose Architrave	Oak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, 1no deadlock, mechanical door closer	Lever on rose handles with escutchean key profile and DLOB Mortice Sashlock 3 Lever	SAA	No	No	Classsroom Door	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)	Master Key Required	
TE0046 - CD0044	Single	12	Single RH	FSC	FD30s	(760mmx150mm) 7mm clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004 Square (450mm x 450mm)	Hardwood	3mm to BS 476 Part 31s	DAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, 1no deadlock, mechanical door closer Handles, kickplates,	Lever on rose handles with escutchean key profile and DLOB Mortice Sashlock 3 Lever	SAA	No	No	Classsroom Door	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s) Intumescent strips to be filted	Master Key Required	
CD0044-OF0043	Door & Half	13	Single LH	FSC	FD30s	7mm clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Free Closing	Square	Yes	Yes (keep shut)	digi lock, mechnical door closer. Half door to be fitted with flush bolts	Lever on rose handles with push button code & tubular latch	SAA	No	Removal Only	Office	to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)		
			Single Both	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1-2014 & BS EN 12600:2004 (full door only)	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Oak	Automatic	Square	Yes	Yes (automatic fire door keep clear)	Dorgard Standard Fire Door Retainer, mechanical door closer, pull handles (one side), kickplates, pushplates (both sides). Half door to be fitted with flush bolts	D Pull Handle (300mm)	544	Yes	Yes	Corridor / Access	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)		
10053 050043	Clock Hait	14	Single LH	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer	Lever on rose handles with push button code & tubular latch	SAA	No	No	Office	Intumescent strips to be filted to both frames and doors (Intumescent seal's should combine cold smoke brush seals for FD30s)		T
L10053-0F0047	Single	15	Single RH	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to B5 EN 1634-1:2014 & B5 EN 12600:2004	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Dak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer	Lever on rose handles with push button code & tubular latch	SAA	No	No	Office	Intumescent strips to be filted to both frames and doors (Intumescent seal's should combine cold smoke brush seals for FD30s)		T
L10053-OF0050	Single	17	Single LH	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer	Lever on rose handles with push button code & tubular latch	SAA	No	Removal Only	Office	Intumescent strips to be fited to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)		
HA0059-LI0053	Door & Half	18	Single Both	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1-2014 & BS EN 12600:2004 (full door only)	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bulinose Architrave	Oak	Automatic	Square	Yes	Yes (automatic fire door keep clear)	Dorgard Standard Fire Door Retainer, mechanical door closer, pull handles (one side), kickplates, pushplates (both sides). Half door to be fitted with flush bolts	D Pull Handle (300mm)	584	Yes	Yes	Corridor / Access	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)		
			Single Both	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004 (full door only)	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Oak	Automatic	Square	Yes	Yes (automatic fire door keep clear)	Dorgard Standard Fire Door Retainer, mechanical door closer, pull handles (one side), kickplates, pushplates (both sides). Half door to be fitted with flush bolts	D Pull Handle (300mm)	544	Yes	Yes	Corridor / Access	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s)		
CD0058-LI0053	Door & Half	19	Single LH	FSC	FD30s	None	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer	Lever on rose handles with push button code & tubular latch	SAA	No	Removal Only	Medical Access	Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke		T
CD0058-ME0051	Single	20	Single RH	FSC	FD30s	None	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer	Lever on rose handles with push button code & tubular latch	SAA	No	No	Office	brush seals for FD30s) Intumescent strips to be fiited to both frames and doors (Intumescent seals should combine cold smoke		t
ME0051-50054	Single	21	Single RH	FSC	FD30s	None	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer	Lever on rose handles with push button code & tubular latch	SAA	No	Removal Only	Store	brush seals for FD30s) Intumescent strips to be fiited to both frames and doors (Intumescent seals should combine cold smoke		t
CD0058-CS0060	Single	22	Single RH	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1-2014 & BS EN 12600-2004	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer	Lever on rose handles with push button code & tubular latch	SAA	No	No	Office	brush seals for FD30s) Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke		t
CD0058-GR0062	Single	23	Single RH	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to 85 EN 1634-1-2014 & 85 EN 12600-2004	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer	Lever on rose handles with push button code & tubular latch	SAA	No	No	Store	brush seals for FD30s) Intumescent strips to be filted to both frames and doors (Intumescent seals should combine cold smoke		t
CD0058-GR0063	Single	24	Single Both	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Cak	Automatic Upgrade	Square	Yes	Yes (automatic fire door	Dorgard Standard Fire Door Retainer, mechanical door closer, pull handles (one side),	D Pull Handle (300mm)	SAA	No	No	Cafeteria / Hall	brush seals for FD30s) Intumescent strips to be filted to both frames and doors	Doors spec'd for automatic upgrade	
DP0074-CD0058	Door & Half	25		FSC	FD30s	1634-1-2014 & BS EN 12600:2004 (full door only) Oblong Glass Pane (760mmx150mm)	Hardwood	3mm to BS 476 Part 31s	DAK	Veneer	Bulinose Architrave	Oak	Self Closing	Square	Yes	keep clear) Yes	kickplates, pushplates (both sides). Half door to be fitted with flush bolts Handles, kickplates, 1no	Lever on rose handles with	SAA	(Consider Automating)	No	Classsroom Door	(Intumescent seals should combine cold smoke brush seals for FD3Ds) Intumescent strips to be filted to both frames and doors	Master Key Required	+
CR0068-CD0058	Bespoke Single	26	Single RH	15.	10305	7mm dear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004 Strip (1450mm x 150mm) 7mm	Hardwood	21000 00 2440 Mar 272	UAL.	veneer	Bulliose Archiolave	Calk	Seri Closing	Square	16	(keep shut) Yes	Dorgard Standard Fire Door Retainer, mechanical door	escutchean key profile and DL03 Mortice Sashlock 3 Lever	544	NO	NO	Cassioni Door	(Intumescent seals should combine cold smoke brush seals for FD30s) Intumescent strips to be fiited	Nusian key negurieo	┼
CD0066-CD0058	Door & Half	27	Single Both	FSC	FD30s	clear Pyrobelite glass to BS EN 1634-12014 & BS EN 12600-2004 (full door only) Strip (1450mm x 150mm) 7mm	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bulinose Architrave	Gak	Automatic Upgrade	Square	Yes	(automatic fire door keep clear)	closer, pull handles (one side), kickplates, pushplates (both sides). Half door to be fitted with flush bolts Dorgard Standard Fire Door Retainer, mechanical door	D Pull Handle (300mm)	544	No (Consider Automating)	No	Corridor / Access	to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s) intumescent strips to be filted	Doors spec'd for automatic upgrade	
HA0059-CD0058	Door & Half	28	Single Both	FSC	FD30s	clear Pyrobelite glass to BS EN 1634-1-2014 & BS EN 12600:2004 (full door only)	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Oak	Automatic Upgrade	Square	Yes	Yes (automatic fire door keep clear)	closer, pull handles (one side), kickplates, pushplates (both sides). Half door to be fitted with flush bolts	D Puli Handle (300mm)	544	No (Consider Automating)	No	Entrance Exit Main Hall	to both frames and doors (Intumescent seals should combine cold smoke brush seals for FD30s) Intumescent strips to be fited	Doors spec'd for automatic upgrade	
CD0066-ST0067	Bespoke Single	29	Single RH	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1-2014 & BS EN 12600:2004	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Oak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer	Level on rose handles with push button code & tubular latch Level on rose handles with	SAA	No	No	Store	to both frames and doors (Inturescent seals should combine cold smoke brush seals for FD30s) 2no. Vision Pannels will require replacement or this door.	5	-
CD0056-8T0073	Single	30	Single LH	FSC	FD30s	None	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, door closer Push and kick plates (both	push button code & tubular latch	SAA	No	No	Store	Intumescent strips to be filted to both frames and doors.		╞
L00071-GT0072	Single	31	Single LH	FSC	Consider FD30 (not required)	None Oblong Glass Pane	Hardwood		OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	None	sides), mechanical door closer, pull handle (one side)	D Pull Handle (300mm)	SAA	No	No	Tollet Door	Intumescent strips not required		+
CR0070-L00071	Bespoke Single	32	Single RH	FSC	FD30s	(760mmx150mm) 7mm dear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004 Strip (1450mm x 150mm) 7mm	Hardwood	3mm to BS 476 Part 31	DAK	Veneer	Bullnose Architrave	Oak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, 1no deadlock, mechanical door closer Handles, kickplates,	Lever on rose handles with escutchean key profile and DL03 Mortice Sashlock 3 Lever Level on rose handles with	544	No	No	Classsroom Door	to both frames and doors. (Intumescent seals should combine cold smoke brush seals for FD30s) Intumescent strips to be filted	Master Key Required	+
CR0018 - ST0019	Single	33 (next to 1)	Single LH	FSC	FD30s	stnp (1450mm x 150mm) /mm clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer Push and kick plates (both	Level on rose handles with push button code & tubular latch	SAA	No	No	Store	to both frames and doors. (Intumescent seals should combine cold smoke brush seals for FD30s)		+
CD0036-DT0035	Bespoke Single	34 (next to 9)	Single LH	FSC	FD30s	None	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	None	sides), mechanical door closer, pull handle (one side)	Disabled toilet indicator bolt	584	No	No	Disabled Toilet	Intumescent strips not required		+
L00071 - ST0065	Single	35 (opposite 31)	Single RH	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1:2014 & BS EN 12600:2004 Strip (1450mm x 150mm) 7mm	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Dak	Self Closing	Square	Yes	Yes (keep shut)	Handles, kickplates, digi lock, mechnical door closer Handles, kickplates, Ino	Level on rose handles with push button code & tubular latch Lever on rose handles with	SAA	No	No	Store	to both frames and doors. (Intumescent seals should combine cold smoke brush seals for FD30s) Intumescent strips to be filted		+
K10063 - GR0062	Single	36 (next to 24)	Single RH	FSC	FD30s	Strip (1450mm x 150mm) 7mm clear Pyrobelite glass to BS EN 1634-1-2014 & BS EN 12600:2004	Hardwood	3mm to BS 476 Part 31	OAK	Veneer	Bullnose Architrave	Cak	Self Closing	Square	Yes	Yes (keep shut)	deadlock, mechanical door	Lever on rose handles with escutchean key profile and DL03 Mortice Sashlock 3 Lever	SAA	No	No	Classsroom Door	to both frames and doors. (Intumescent seals should combine cold smoke brush seals for FD30s)	Master Key Required	+
			$\vdash$	+																				Total	
<u>.</u>		_																							

al o