



LEGEND:

	COMBINED SEWER
	FOUL SEWER
	SURFACE WATER TUNNEL
	SURFACE WATER SEWER
	TELECOM
	GAS LOW PRESSURE
	GAS MEDIUM PRESSURE
	HV ELECTRIC
	LV ELECTRIC
	33 kV ELECTRIC
	POTABLE WATER
	ABANDONED POTABLE WATER

Notes

- ALL DIMENSIONS ARE IN MILLIMETRES AND ALL LEVELS ARE IN METRES UNLESS SHOWN OTHERWISE.
- ALL LEVELS ARE TO JERSEY DATUM PLUS 100m.
- DO NOT SCALE - IF IN DOUBT ASK.
- ALL EXISTING DIMENSIONS, LEVELS, SIZES AND OTHER NECESSARY DETAILS SHALL BE CONFIRMED ON SITE BY THE CONTRACTOR.
- ALL STEELWORK SHALL BE GRADE 316 EXCEPT WHERE SHOWN OTHERWISE.
- CONCRETE MINIMUM REQUIREMENTS:
 - STRUCTURAL CONCRETE SHALL BE GRADE C28/35.
 - MASS CONCRETE AND BENCHING SHALL BE GRADE C25/30.
 - BLINDING CONCRETE SHALL BE GRADE C16/20.
 - ALL INTERNAL EXPOSED FORMED FACES SHALL BE 'FAIR FINISH'.
 - ALL EXTERNAL EXPOSED FORMED FACES SHALL BE 'FAIR WORKED FINISH' TO 300mm BELOW GROUND LEVEL.
 - ALL EXPOSED HORIZONTAL EDGES OF CONCRETE SHALL HAVE 25x25mm CHAMFERS TO 150mm BELOW GROUND.
- PAINTING SYSTEMS SHALL BE CATEGORY C5M TO PROVIDE 20 YEAR MINIMUM DURABILITY.

LEGEND

	PROPOSED NEW WORK - VENT STACK AND ASSOCIATED WORKS
--	---

SWECO HEALTH AND SAFETY INFORMATION

IN ADDITION TO THE HAZARDS NORMALLY ASSOCIATED WITH THE TYPES OF WORK DETAILED ON THIS DRAWING, PLEASE NOTE THE FOLLOWING:

CONSTRUCTION/DEMOLITION PHASE	ACTION REQUIRED TO CONTROL THE RESIDUAL RISK
1. CONFINED SPACE WORKING WITH RESTRICTED ACCESS	
2. WORKING AT HEIGHT	
3. WATER INUNDATION, RISK OF FLOODING	
4. WORKING IN RESTRICTED AREAS NEAR THE PUBLIC	

ACCESS - HORI, VERT, PEDESTRIAN, VEHICLE/PLANT
POINTS REQUIRING ACCESS: METHOD OF ACCESS:

HANDLING/LIFTING STRATEGY
ITEMS REQUIRING HANDLING: METHOD OF HANDLING:

IT IS ASSUMED THAT ALL WORKS WILL BE CARRIED OUT BY A COMPETENT PERSON WORKING, WHERE APPROPRIATE, TO AN APPROVED SAFE SYSTEM OF WORK

DRAWING REFERENCE

119428-12-1000	WEIGHBRIDGE CSO AND SHAFT S1 EXISTING SITE PLAN
119428-12-1003	SHAFT S1 PROPOSED LAYOUT AND ELEVATIONS

NOTE: CONTRACTOR TO INSTALL VENTED STEEL PLATES SECURELY FIXED TO CONCRETE ABOVE ANY OPENING PRIOR TO VACATING THE SITE ON DAILY BASIS OUT OF HOURS

Rev.	Date	Amendment Details	Orig	Chk'd	App'd
02	05.04.19	FOR TENDER	KS	JB	JH
01	18.01.19	FOR INFORMATION	KS	JB	JH

This drawing should not be relied on or used in circumstances other than those for which it was originally prepared and for which Sweco was commissioned. Sweco accepts no responsibility for this drawing to any party other than the person by whom it was commissioned. This drawing has been prepared for the titled project or named part thereof and should not be relied upon or used for any other project without an independent check being carried out as to its suitability and prior written authority of Sweco being obtained. Sweco accepts no responsibility or liability for the consequences of this drawing being used for a purpose other than the purposes for which it was commissioned. Any person using or relying on this drawing for such other purpose agrees, and will by such use or reliance be taken to confirm his agreement, to indemnify Sweco for all loss or damage resulting therefrom.

Sweco
Grove House
Mansion Gate Drive
Leeds
LS7 4DN
Tel: +44 (0)113 262 0000
Web: www.sweco.co.uk

Client
States of Jersey
GROWTH, HOUSING & ENVIRONMENT

PO BOX 412
BERESFORD HOUSE
BELLOZANNE ROAD
ST HELIER
JE4 8UY
Tel: 01534 445509
Fax: 01534 445529

Drawing Status: **FOR TENDER**

Project Title: **WEIGHBRIDGE CSO AIR RELEASE**

Drawing Title: **WEIGHBRIDGE CSO AND SHAFT S1 PROPOSED SITE PLAN**

Scale	Originator	Drawn	Checked	Approved
1:50	S.M.	RGB	J.B.	J.H.
Original Size	Date	Date	Date	Date
A1	14.01.19	22.02.19	05.04.19	05.04.19
Drawing Number	Revision			
119428-12-1002	02			

