4No 13A SWITCHED FUSED CONNECTION UNITS FOR WARDEN CALL/DOOR ENTRY EQUIPMENT SUPPLIED AS DEDICATED POWER CIRCUIT CONTRACTOR TO LIAISE WITH SPECIALIST CONTRACTOR FOR FINAL CONNECTION TO EQUIPMENT AS NECESSARY.

13A SWITCHED FUSED CONNECTION UNITS FOR FIRE ALARM DOOR CLOSER EQUIPMENT. SUPPLIED AS DEDICATED POWER CIRCUIT CONTRACTOR TO LIAISE WITH SPECIALIST CONTRACTOR FOR FINAL CONNECTION TO EQUIPMENT AS NECESSARY.

INCOMING SERVICE AND METERING EQUIPMENT POSITION FOR THE HOME. CONTRACTOR TO ALLOW FOR THE RATIONALISATION OF THE EXISTING EQUIPMENT, THE INSTALLATION OF A NEW 160A T.P.& N. MAIN SWITCH AND THE PROPOSED NEW DISTRIBUTION BOARD LP1.

DISTRIBUTION BOARD WARDENS

LP1

THE EXISTING DISTRIBUTION BOARDS ARE TO BE RETAINED AND RE-FED FROM THE NEW DISTRIBUTION BOARD LP1.

Existing Electrical Installation to be Retained

Existing Electrical Installation to be Retained

Existing Electrical Installation to be Retained

Route of Lift Motor Pipework and Control Wiring

GROUND FLOOR